

Monson Fire Department
Food Truck/Trailer Checklist

VEHICLE NAME: _____

LICENSE PLATE #: _____

OWNER NAME: _____

OWNER ADDRESS: _____

OWNER CONTACT #: _____

General:

Current DOT Vehicle Inspection Sticker? (DATE: _____)

- Yes No N/A

Hood:

Type I serviced and inspected within applicable date (527 CMR 1.00: Table 50.5.4) (DATE: _____)

- Yes No N/A

Free of deposits from grease laden vapors (527 CMR 1.00: 50.5.4)

- Yes No N/A

Suppression System

Tested within the last 6 months (527 CMR 1.00 § 50.5.2.1) (DATE: _____)

- Yes No N/A

Extinguisher(s): (527 CMR 1.00 § 50.4.4.1)

Minimum 10-B:C (1: 69.3.12.8)

- Yes No N/A

K: if grease laden vapors, vegetable or animal oils, or fats used (527 CMR 1.00 § 50.4.12.2)

- Yes No N/A

Service tag(s) present and up-to-date (527 CMR 1.00: 13.6.4.3.4.1) (DATE: _____)

- Yes No N/A

Extinguisher(s) located near doorway and accessible (527 CMR 1.00: 13.6.3.1.3)

- Yes No N/A

Generator: (527 CMR 1.00 § 11.7.2.2)

Exhaust directed at least 5-feet in any direction away from any openings or air intakes

- Yes No N/A

(OVER)

Deep fat fryer:

8" tall steel or tempered glass baffle plate or 16" of space between a deep-fat fryer and surface flames from adjacent cooking equipment (527 CMR 1.00 §50.6.1.2.4 & 50.6.1.2.5)

- Yes No N/A

Have any cooking appliances been moved, modified, or rearranged?

- Yes No N/A

- o If yes, has a re-evaluation of the fire-extinguishing system been performed? (527 CMR 1.00 § 50.6.1.2.2)

Propane:

Amount: _____ pounds

Securely mounted to vehicle or rear-mounted within cabinet (vented to outside, vapor-tight to inside)(1:69.3.12.3.4)

- Yes No N/A

If cylinder(s) is located on the outside of the vehicle, is weather protection provided (1: 69.3.12.3.4.8)

- Yes No N/A

If cylinder(s) is located on the outside of the vehicle, does bumper extend beyond tank (1: 69.3.12.3.4.1)

- Yes No N/A

Hydrostatic test date within range: _____ (Within 12 years of manufacture or 5 years of retest) (49 CFR 180.205)

- Yes No N/A

Cylinder in good condition (no rust, no dents, etc) (527 CMR 1.00: 69.2.1.1.4)

- Yes No N/A

Less than 200 gallon aggregate water capacity (1:69.3.12.3.1.2)

- Yes No N/A

Is piping in good condition (527 CMR 1.00: 69.3.12.5)

- Yes No N/A

Gasoline:

Less than 21 gallons otherwise permit required; No container larger than 7-gallons (1: 1.12.8.25.3.5.1)

- Yes No N/A

Recommendations/Reminders:

- 3-in-1 Propane hazard sign placed on the outside of the vehicle as close to the tank as possible ("Danger" "Propane" "No Smoking – No Open Flames")
- Have a professional check the integrity of the gas lines
- Install a CO Detector
- Generator: uninterrupted operation; refueled only when engine is shut down and cool; isolated from contact with the public (1: 10.14.10.1 & 1: 10.14.10.3)
- Provide 10-feet of clearance from adjacent food truck (1: 10.14.8)
- Present Fire Safety Tips for Mobile Cooking Operations handout to applicant
- Present US DOT Food Truck Operation (propane) handout to applicant

INSPECTION PERFORMED BY: _____ DATE: _____